

City of Dixon Collections System  
Sewer Callout & SSOs Overview Log 1998 to Present

Sewer Callouts Overview by Year and Cause	Sewer Callouts Years																		Totals		
	1998	1999	2000	2001	2002	2003	2004	2005	2006	2007	2008	2009	2010	2011	2012	2013	2014	2015			
	Total Sewer Calls Regular & After Hours	14	28	24	33	25	32	32	42	30	36	30	28	5							359
	Sewer Odor Complaints	2	1	1		1	5	2	1		2	1	3								19
	Sewer Mainline Blockages*	4	8	5	12	9	6	10	12	2	9	1	8	1							87
	*Roots	1	3	1	3	4	1	4	4	1	3		1								26
	*Grease		1	1	3	3	2	4	7	1	4	1	5								32
	*Debris	3	1	3	4	2	4	3	1		2	1	5	1							30
	*Vandalism		1				1														2
	*Infrastructure Failure		2					1													3
	*Unknown Cause						2	1	1												4
	Private Lateral Blockage	8	19	18	21	16	22	21	29	28	27	28	18	3							258
	Call Outs Regular Hours	8	19	16	13	8	22	19	22	20	25	19	17	2							210
	Call Outs After Hours	6	9	8	20	17	10	13	20	10	11	11	11	3							149
	Response Time Less Than 30 Minutes	14	28	24	33	25	32	32	42	30	36	30	28	5							359
	Response Time Greater Than 30 Minutes																				

Number of SSOs per Category and Gallons City Owned Assets	City Owned Assets																		Totals		
	1998	1999	2000	2001	2002	2003	2004	2005	2006	2007	2008	2009	2010	2011	2012	2013	2014	2015			
	Greater than or equal to 1000 gallons (Category 1)																				
	From 100 to 999 gallons (Category 2)								2												2
	From 1 to 99 gallons (Category 2)								1	1											2
	Volume of SSOs in gallon per Year																				
	Total volume contained and returned to the sewer system								220	5											225
	Total volume reaching surface waters of the State																				
Total volume not contained, but did not reach surface waters of the State																					
<b>Total</b>								220	5										225		

Number of SSOs per Category and Gallons Private Laterals	Private Laterals or Private Systems																		Totals		
	1998	1999	2000	2001	2002	2003	2004	2005	2006	2007	2008	2009	2010	2011	2012	2013	2014	2015			
	Greater than or equal to 1000 gallons (Category 1)																				
	From 100 to 999 gallons (Non-Reportable)																				
	From 1 to 99 gallons (Non-Reportable)						1		2	3	3		1								10
	Volume of SSOs in gallon per Year																				
	Total volume contained and returned to the sewer system						20		35	30	90		5								180
Total volume reaching surface waters of the State																					
Total volume not contained, but did not reach surface waters of the State																					
<b>Total</b>						20		35	30	90		5							180		

Causes of SSOs to City Owned Assets	Causes of SSOs From City Owned Assets																		Totals		
	1998	1999	2000	2001	2002	2003	2004	2005	2006	2007	2008	2009	2010	2011	2012	2013	2014	2015			
	Roots																				
	Grease								2												2
	Debris								1	1											2
	Debris from Laterals																				
	Vandalism																				
	Animal Carcass																				
	Construction Debris																				
	Multiple Causes																				
	Infrastructure Failure																				
	Inflow & Infiltration																				
	Electrical Power Failure																				
	System Capacity Deficiency																				
Natural Disaster																					
Bypass																					
Unknown Cause																					
<b>Total</b>								3	1										4		



## City of Dixon Collections System Manhole, Cleaning, Flushing & CCTV Totals



Year	Manhole Inspections	Sewer Line Cleaning Miles	Sewer Line Flushing Miles	Sewer Line CCTV Miles
2005	33	1.48	0.00	0.08
2006	16	0.79	0.00	0.02
2007	397	5.64	1.09	0.29
2008	0	0.00	0.00	0.00
2009	0	3.67	1.25	2.04
2010	38	0.27	0.00	0.22
2011	2	0.00	0.00	0.00
2012	0	0.00	0.00	0.00
2013	0	0.00	0.00	0.00
2014	0	0.00	0.00	0.00
2015	0	0.00	0.00	0.00
2016	0	0.00	0.00	0.00
2017	0	0.00	0.00	0.00
2018	0	0.00	0.00	0.00
2019	0	0.00	0.00	0.00
2020	0	0.00	0.00	0.00
2021	0	0.00	0.00	0.00
Total	486	11.85	2.34	2.65